

GOVERNMENT OF TRIPURA
SUB-DIVISION LEVEL WATER TESTING LABORATORY
UNDER DWS SUB-DIVISION SANTIRBAZAR
SANTIRBAZAR, SOUTH TRIPURA, PIN-799144
PWD(DWS)



WATER TEST REPORT


Sample ID:- SLWTL/DWS/STB/26/616
Source/Location:- BC Manu SS Vidyamandir School
Habitation/Ward:- -
GP/VC/MNC:- - BC Nagar VC
Block:- - Bokafa
District:- South Tripura
State:- Tripura
Date of Collection:- 13-08-2026
Date of Received:- 13-08-2026
Date of Testing:- 13-08-2026
Sample Collector:-

Sl. No.	Parameter	Unit	Max. Requirement as per BIS 10500	Max Permissible Limit as per BIS 10500	Test Result	Remarks
1	Odor	NA	Agreeable	Agreeable	Agreeable	
2	Taste	NA	Agreeable	Agreeable	-	
3	Color	Hazen Units	5	15	02	
4	pH	NA	6.5-8.5	No relaxation	6.86	
5	Turbidity	NTU	1	5	0.37	
6	TDS	mg/l	500	2000	89	
7	Total Hardness	mg/l	200	600	62	
8	Alkalinity	mg/l	200	600	30	
9	Iron	mg/l	1	No relaxation	0.163	
10	Chloride	mg/l	250	1000	13.5	
11	Calcium	mg/l	75	200	-	
12	Magnesium	mg/l	30	100	-	
13	Free Residual Chlorine	mg/l	0.2	1	0	
14	Fecal Coliform	MPN/100ml	0	No relaxation	-	
15	Total Coliform	MPN/100ml	0	No relaxation	0	

Analysed by


[Chemist]


[Microbiologist]


Lab In-Charge
Sub-Division Level Water Testing Laboratory
PWD(DWS), Santirbazar, Tripura [S]

(This is the end of the Report)

Government of Tripura
Office of the Medical Officer In-Charge
B.C MANU MEMORIAL PRIMARY HEALTH CENTRE
Health & Wellness Centre - AYUSHMAN BHARAT
B.C Nagar, Santirbazar South District, Tripura

File No. Sample Id no | SLWTL/DNS/STD | 26/616

Dated, 20/08/26

CERTIFICATE FOR SAFE DRINKING WATER AND SANITARY CONDITION

I hereby declared that the **B.C Manu SS Vidyamandir Higher Secondary School, B.C Nagar, Santirbazar South District, Tripura** building, premises & accommodation provide for each of the several classes is sufficient for all maximum number of pupils taught there in properly ventilated and lighted that is neat & clean that the urinals & latrines arrangements are adequate and satisfactory that the supply of **drinking water is wholesome and in all other respect the hygienic & sanitation is good for the Academic year 2026-2027.**

It is also found that, the health condition of the pupils, Teacher & other staffs of the School are healthy & free from communicable diseases and nutrition status of the student is good.


Medical Officer In-Charge
B.C Manu Memorial Primary Health Centre
B.C Nagar, Santirbazar South Tripura



To
The Principal
B.C Manu SS Vidyamandir H.S School
B.C Nagar, Santirbazar South Tripura